

RefPlus Air Cooled Condenser Rating

Sound Pressure Rating in DBA at 10 Ft from the unit

| Model | Fan arrangement | | | | | | | | | |
|-------|-----------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| | 1X1 | 1X2 | 1X3 | 1X4 | 1X5 | 2X2 | 2X3 | 2X4 | 2X5 | 2X6 |
| CCD | 56 | NA | NA | NA | NA | NA | NA | NA | NA | NA |
| CMD | 62 | 65 | 67 | NA | NA | NA | NA | NA | NA | NA |
| CQD | 55 | 58 | 59 | 60 | 61 | 60 | 62 | 64 | 65 | 66 |
| CLD | 62 | 65 | 66 | 67 | 68 | 67 | 69 | 71 | 72 | 73 |
| CHD | 65 | 68 | 69 | 70 | 71 | 70 | 72 | 74 | 75 | 76 |
| CID | 72 | 75 | 76 | 77 | 78 | 77 | 79 | 81 | 82 | 83 |
| CVD-L | 51 | 54 | 55 | 56 | 57 | 56 | 58 | 60 | 61 | 62 |
| CVD-H | 59 | 62 | 63 | 64 | 65 | 64 | 66 | 68 | 69 | 70 |

Sound rating are evaluated from test done on model CLD 8 fans unit and CVD 4 fans unit at both speeds

Sound rating are for vertical air flow unit.

Actual sound rating may vary depending of background and mounting arrangement

Nov.27, 2007